


LTR	DATE	REVISION	BY	REPRESENTATIVE
				X
				PROJECT:
				X

NOTES			CHECKED BY	DATE	THIS DRAWING IS THE PROPERTY OF SUPERIOR BOILER WORKS & SHALL NOT BE REPRODUCED IN PART OR IN WHOLE, & NONE OF ITS INFORMATION SHALL BE REVEALED WITHOUT PERMISSION OR TO THE DETRIMENT OF THE OWNER. IT MUST BE RETURNED UPON REQUEST.
1. ALL CONTROLS MOUNTED AS PER SPECIFICATION SHEET. 2. SPECIFICATION SHEET TAKES PRIORITY OVER R & D SHEET. 3. REAR DOOR SWING: (1) MIN SIDE, MAX REAR (2) MAX SIDE, MIN REAR 4. BOILER DESIGN CODE ASME SECTION <u>IV</u> . 5. BOILER INSULATED WITH 2" - 8# DENSITY MINERAL FIBER INSULATION WITH 22 GAUGE STEEL JACKET. 6. ALL DIMENSIONS ARE ±1/2" UNLESS OTHERWISE NOTED. *7. HORSEPOWER & RELATED INFO BASED ON 5 SCF/FI FIRING.			DRAWN BY	DATE	
		APACHE	?		
		BOILER MODEL			
		5-8-300-S15			
		SCALE	DRAWING No		
		1/40	?		