



H- STAND HEIGHT SUBJECT TO PUMP NPSH REQUIREMENTS  
 ALL COMPONENTS CONTINGENT UPON FINAL ENGINEERING.  
 PANEL SIZE MAY VARY DEPENDING ON JOB REQUIREMENTS.

TANK CONNECTIONS			PUMP DATA		STEAM VALVE		REVISIONS				THIS DRAWING IS THE PROPERTY OF SUPERIOR BOILER AND SHALL NOT BE REPRODUCED IN PART OR IN WHOLE, AND NONE OF ITS INFORMATION SHALL BE REVEALED WITHOUT PERMISSION OR TO THE DETRIMENT OF THE OWNER, IT MUST BE RETURNED UPON REQUEST.			
A.	(2) OUTLET	2" x 6" NIPPLE IN.	MAKE	GRUNDFOS	MAKE	8221G011	LTR.	DATE	CHANGE	BY				
B.	(1) RETURN	2 1/2 IN.	MODEL	CR3-15 K	SIZE	1 1/2 IN.					SOLD TO:	XXX		
C.	(1) DRAIN	1 IN.	DISCHARGE	1 1/4							JOB:	XXX		
D.	(1) OVERFLOW	2 1/2 IN.	SUCTION	1 1/4	THERMOMETER						DRAWN BY:	XXX	DATE	
E.	(1) HEATER	2 IN.	CAPACITY	13.5 GPM	MAKE PRECISION 163 F						DATE	XXX	CHECKED BY:	
F.	(1) AQUASTAT	1/2 IN.	AT	160 PSIG									DATE	
G.	(1) THERMOMETER	1/2 IN.	MOTOR DATA		RANGE	40-280 F	PRESS. RED. VAL.		TANK WEIGHT: 537 LBS. W/ PUMPS: 977 LBS.		DRAWING NAME			
H.	(1) FEED	3/4 IN.	H.P.	3 RPM 3500	AQUASTAT		MAKE 0-16-N-0009-B				FEEDWATER TANK SYSTEM			
J.	(2) GAUGE	1/2 IN.	VOLTAGE	480/60/3	MAKE L6006A		SIZE 1 1/2 IN.				MODEL NO: S3			
K.	(1) VENT	2 1/2 IN.	STARTER INCLUDED		MODEL 1145		Superior Boiler, Inc. reserves the right to furnish trim shown or an equal substitute as determined by Superior Boiler, Inc.				SIZE: 100 GALLONS			
L.	(1) CHEM. FEED	1 1/2 IN.	MAKE-UP VALVE DATA		RANGE 100-240 F									
M.	( )	IN.	MAKE UB 3060								SCALE 1/18		DRAWING No	
N.	( )	IN.	SIZE 3/4 IN.								SUPERIOR BOILER		XXX	
P.	( )	IN.												